

MT. SAN JACINTO COMMUNITY COLLEGE DISTRICT
ADDENDUM NO. 2
BID NO. 2019-020
MARQUEE ENTRANCE SIGN RENOVATION AT SJC

May 29, 2019

Owner:

Mt. San Jacinto Community College District
1499 N. State Street
San Jacinto, CA 92583

**RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PROPOSAL WHEN
SUBMITTED**

Addendum No. 2

QUESTIONS:

- Q1. Will the primary signs LED message display be 4' x 12' with a matrix of at least 72 x 216?
- A1. Yes
- Q2. Will the primary id sign be at least 18" x 12'?
- A2. Yes
- Q3. Will the secondary LED display be 3' x 10' with a matrix of at least 54 x 180?
- A3. 3.5' x 8.3' matrix to be at least 54 x 144
- Q4. What is the height of the secondary id sign?
- A4. 3.5'
- Q5. Regarding the rock work on double face sign: The type and name of the rock should be specified so that all contractors are bidding apples to apples. Can you provide that information please?
- A5. Synthetic veneer, please submit samples for District approval.
- Q6. The specs call out communication to be wireless and broadband with a lifetime data plan, which is it please?
- A6. Broadband – independent of District network
- Q7. The matrix on the specs do not match the inches. Can we go by the inches and provide you the correct matrix on the product we are supplying?
- A7. Yes
- Q8. Is the matrix a true 16 mm, like 16.0 or is it like a 16.9 mm closer to 17 mm?
- A8. 16mm